



No. 0307/ 7158

To Elite Decor Co., Ltd.

The Department of Science Service presents the test report for the sample named "Plaster Glue Kley" Laboratory No. L58/03246.1 as the total of 1 sample with reference to the request No. L58/03246 dated 3 June 2015.

Enclosed herewith the following result avails for your acknowledgement.

Department of Science Service



Wan

Physics and Engineering Program

Tel. 0 2201 7130

Fax 0 2201 7127

E-mail : physics@dss.go.th

**TEST REPORT****Sample's name**

Plaster Glue Kley

Mark / Brand

-

Laboratory No.

L58/03246.1

Test Result

Bond strength between concrete and light weight cornice at 2 days, MPa 0.10

Customer's name Elite Decor Co., Ltd.

Customer's address 964 Moo 4, Huatale, Nakhon Ratchasima 30000

Sample's description White gel

Test date 4 - 11 June 2015

Test method ASTM C 952-02

Approved by

(Mr. Anon Pomprasit)

Scientist, Senior Professional Level

Reported by

(Mr. Kritsada Suttipan)

Scientist, Professional Level